



LOURDES A. LEON GUERRERO  
GOVERNOR (MAGA'HAGA)

JOSHUA F. TENORIO  
LIEUTENANT GOVERNOR  
(SIGUNDO MAGA'HAGA)

## DEPARTMENT OF ADMINISTRATION

### GENERAL SERVICES AGENCY

AHENSAN SETBISION HINIRAT  
148 ROUTE 1 SOUTH MARINE CORPS DRIVE, PM, GU 96915  
TELEPHONE: (671) 475-1707/1708  
FAX: (671) 472-4217/1727  
EMAIL: [GSAPROUREMENT@GSADOA.GUAM.GOV](mailto:GSAPROUREMENT@GSADOA.GUAM.GOV)  
WEBSITE: [WWW.GSA.DOA.GUAM.GOV](http://WWW.GSA.DOA.GUAM.GOV)



EDWARD M. BIRN  
DIRECTOR (DIREKTOT)

BERNADINE C. GINES  
DEPUTY DIRECTOR  
(SIGUNDO DIREKTOT)

July 27, 2021

### Invitation For Bid GSA-032-21 20-Ton Split Ducted A/C Unit

Questions received from JWS Refrigeration and Air Conditioning LTD. July 7, 2021

#### Question 1:

Specification: Provides corrosion protective coating on the new A/C unit's condensing coils  
We intend to offer copper to copper condensing coil. Due to its durability and higher heat transfer efficiency, copper to copper condensing coil is far superior than a standard condensing coil with added protective coating. We kindly request to include "Cooper to Copper Condensing Coil"

Response: Your request has been denied, specifications will remain as is.

#### Question 2:

Specification: Delivery /completion (includes ordering, installation, and testing of unit) time is within 9-11 weeks from date of award (or sooner)

Due to the Pandemic and the precautionary measure and safely of Shipping/Logistics. We kindly request the original specification be amended to reflect the following "within 16-18 weeks from date of award (or sooner)"

Response: Your request to amend the delivery/completion date has been denied. This is grant funded and must be obligated on or before September 30, 2021.

  
CLAUDIA S. ACFALLE  
Chief Procurement Officer

Please Print  
Acknowledgement Copy (Re-Fax to GSA)

Received By: \_\_\_\_\_  
Date: \_\_\_\_\_  
Company Name: \_\_\_\_\_  
Fax to: 475-1727 or 472-4217  
Email to: [gsaprourement@gsadoa.guam.gov](mailto:gsaprourement@gsadoa.guam.gov)